NO FIREWORKS 4"
DISCHARGE 4"
WITHIN 300 FEET 4"

Section 7.4.6.3 - 2013 edition NFPA 1124
At least one (1) sign shall be posted on each exterior side of the CFRS facility. Letters shall be 4" high and have a contrasting background.
Choose one of these two options.

NO FIREWORKS DISCHARGE 4"
WITHIN 300 FEET 4"