

FIREWORKS - NO SMOKING

2"

Section 7.3.10.2 - 2013 edition NFPA 1124

At least one (1) sign shall be conspicuously posted at each entrance of the CFRS facility. Letters shall be 2" high and have a contrasting background.

Choose one of these two options.

FIREWORKS

2"

NO SMOKING

2"