

FIREWORKS - NO SMOKING

4"

Section 6.11.6 - 2013 edition NFPA 1124

At least one (1) sign shall be conspicuously posted on the outside of the CFRS storage facility. Letters shall be 4" high and have a contrasting background.

Choose one of these two options.

FIREWORKS

4"

NO SMOKING

4"