

**PURPOSE**

To define the procedure, roles, and affix responsibilities for completing annual fire apparatus pump testing in accordance with NFPA standards.

**POLICY**

It is the policy of the Peoria Fire Department that all fire apparatus equipped with fire pumps receive a pump test, in accordance with NFPA 1911, Service Test of Fire Pump systems on fire Apparatus. These tests shall be performed at least annually or after major repairs or modifications to the pump are performed.

**Procedure**

The fire department Physical Resource Supervisor shall initiate pump testing for each apparatus.

- Each apparatus shall be scheduled through the Sr. Fire Tech. for testing.
- The Physical Resource Supervisor shall insure that the Sr. Fire Tech is provided with a current version of NFPA 1911 prior to scheduling pump testing.
- Pump test result shall be recorded on appropriate forms as indicated in NFPA 1911, "Service Tests Results" and "Capacity Test".
- The Physical Resource Supervisor and Sr. Fire Tech. shall maintain copies of all completed pump test records and certifications.
- Pump test records and certifications shall be maintained for a period of not less than three years for each apparatus.



Approved: \_\_\_\_\_

Robert McKibben, Fire Chief

10/5/04

Date