



Building Development

9875 N. 85th Avenue
 Peoria, AZ 85345
 Phone: 623-773-7225
 Fax: 623-773-7245

building.applications@peoriaaz.gov
www.peoriaaz.gov/building

Permit#: _____

For Office Use Only

Critical Life & Health Safety Matrix Audit Scoring - Buildings

Plan Review Discipline	Subject Matter Category	Points
Architecture	• Not enough exits	2 points
	• Inaccurate occupancy count	2 points
	• Fire ratings inadequate	2 points
	• Height and area limits exceeded	2 points
Structural	• Incorrect design loads	3 points
	• Structural elements inadequate	5 points
Electrical	• Full system failure	3 points
Plumbing	• Non-compliant gas piping system	2 points
Mechanical	• Non-compliant outside air calculations	2 points
	• Non-compliant kitchen grease hood system	2 points