

## CHAPTER 25 - WATER, SEWERS AND SEWAGE DISPOSAL

### Sec. 25-171. Interceptors -- Required.

(a) Grease, oil, lint, sand or other interceptors shall be required for laundries, restaurants, service stations, auto repair shops, car washes and other facilities when, in the opinion of the Director, they are necessary for the proper handling of liquid wastes containing grease or oil in excessive amounts or any flammable wastes, sand, or any other substance considered by the Director to have the potential to adversely affect the POTW.

(b) All internal interceptors shall be required for those facilities that will have minimal fixtures being discharged and require minimal retention time. The minimum internal interceptor shall be no smaller than a device rated at 50-gallon-per-minute flow with a 100-pound grease capacity (50/100). A flow control device shall be installed upstream of the interceptor and in accordance to manufacturer's specifications.

(c) All external interceptors shall be required for those facilities that will have numerous fixtures being discharged and require extended retention time. The minimum external interceptor shall be no smaller than a two compartment container rated at 500-gallon capacity and no larger than a three compartment container rated at 2500-gallon capacity. All external interceptors shall be installed according to City of Peoria Standard Detail PE-450 and must include a sample vault.

(Ord. No. 87-43, § III(12-2-12), 9-22-87)

(Ord. No. 90-11, 4/10/90)

(Ord. No. 91-41, 11/12/91)

(Ord. No. 02-41, 6/7/02, Amended) SUPP 2002-2

(Ord. 04-197, 9/21/04, Amended) SUPP 2004-3

(Ord. No. 09-39, 10/20/09, Amended) SUPP 2009-4