

CHAPTER 5 – BUILDINGS AND BUILDING REGULATIONS

Sec. 5-118. Booster pumps.

Where a booster pump has been installed on the service line to or within any premises, such pump shall be equipped with a low pressure cutoff device designed to shut off the booster pump when the pressure in the service line on the suction side of the pump drops to twenty (20) pounds per square inch or less. It shall be the duty of the water consumer to maintain the low pressure cutoff device in proper working order and to certify to the department at least once a year that the device is operable.

(Code 1977, § 8-2-11)