



# PEORIA FIRE DEPARTMENT

8351 West Cinnabar Avenue  
Peoria, Arizona 85345

## Inspection Guide for Temporary Retail of Consumer Fireworks

This guide is an outline to assist the Fire Inspector for temporary retail locations such as tents and stands. This guide is not inclusive of all requirements in the IFC and NFPA 1124. This guide includes some of the applicable code/standard sections for reference. This guide contains the minimum requirements set forth by the Valley Fire Marshal's Association for consumer fireworks retail sales.

<b>Consumer Fireworks Retail Sales (CFRS) Inspection</b>			
	Pass/Yes	Fail/No	N/A
Identify the amount (pounds) of Consumer Fireworks. Where the actual weight of the pyrotechnic composition is not known, 25% of the gross weight including packaging can be used to determine exempted amounts. (NFPA 1124 – 7.3.1.1 and 7.3.1.2) <input type="checkbox"/> Less than 500 lbs in a non sprinklered building (exempt) <input type="checkbox"/> 500 lbs or more in a non sprinklered building <input type="checkbox"/> Less than 1,000 lbs in a sprinklered building (exempt) <input type="checkbox"/> 1,000 lbs in a sprinklered building	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Identify the type of inspection and that a permit has been issued for. <input type="checkbox"/> Retail location (NFPA 1124 – 7.3.2) <input type="checkbox"/> Tent/Canopy/Membrane Structure (NFPA 1124 – 7.3.2) <input type="checkbox"/> Stand (NFPA 1124 – 7.3.2) <input type="checkbox"/> Storage (NFPA 1124 – 6.3.1) <input type="checkbox"/> Other	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Verify that a permit has been issued for the following other permits. <input type="checkbox"/> Temporary Use Permit (TUP) from Planning and Zoning. <input type="checkbox"/> Generators 25kw or greater from Building Safety. <input type="checkbox"/> New electrical panels or circuits from Building Safety <input type="checkbox"/> CFRS stands greater than 200 square feet from Building Safety. <input type="checkbox"/> Other	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Identify whether the occupancy, CFRS structure, tent, stand or storage structure has an automatic fire sprinkler system installed and is properly tagged. Reductions allowed can only be given on properly maintained systems. (NFPA 1124 – 7.3.1.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS structure, tent, stand or storage container is within one hundred fifty (150) feet from an approved fire apparatus access road (NFPA 1124 – 7.3.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS facility has a minimum of two (2) portable fire extinguishers with a minimum 2A rating. One (1) of these extinguishers must be a pressurized water type. (NFPA 1124 – 7.3.6.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
“NO SMOKING” signs are posted that prohibits smoke inside or within fifty (50) feet of the CFRS facility. (NFPA 1124 – 7.3.11.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
A “FIREWORKS – NO SMOKING” sign is posted at each entrance or within ten (10) feet of every aisle of any CFRS area. The lettering must be a minimum of two (2) inches high. (NFPA 1124 – 7.3.11.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS facility is located more than fifty (50) feet from <u>any</u> propane/compressed natural gas dispensing stations or above ground storage tanks for flammable or combustible liquids, flammable gas or flammable liquefied gas. (NFPA 1124 – 7.3.12.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS facility is located more than fifty (50) feet from <u>any</u> motor vehicle fuel dispensing station dispensers. (NFPA 1124 – 7.3.12.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS facility has an approved fire safety and evacuation plan in writing and is maintained. (NFPA 1124 – 7.3.13)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS retail sales area has a minimum of three (3) exits. (NFPA 1124 – 7.3.14.1.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The maximum egress travel distance from the most remote area does not exceed seventy five (75) feet. (NFPA 1124 – 7.3.14.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Aisles have a minimum clear width of forty eight (48) inches. (NFPA 1124 – 7.3.14.3.1.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Aisles are unobstructed while the facility is occupied. (NFPA 1124 – 7.3.14.3.1.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

	Pass/Yes	Fail/No	N/A
Other required exits are located at or within ten (10) feet of the end of an aisle or cross aisle. (NFPA 1124 – 7.3.14.3.2.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Aisles terminate at an exit, another aisle or cross aisle. (NFPA 1124 – 7.3.14.3.2.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
There are no dead end aisles within the CFRS facility. (NFPA 1124 – 7.3.14.3.2.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Where cross aisles are required, not less than one cross aisle shall have at least one end terminate at or within ten (10) feet of an exit. (NFPA 1124 – 7.3.14.3.2.7)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Any egress door that has a latching device is provided with panic hardware complying with NFPA 101. (NFPA 1124 – 7.3.14.4.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Any means of egress door is a single hinge swinging type and is arranged to swing in the direction of egress travel. (NFPA 1124 – 7.3.14.4.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Continuous displays of packaged fireworks do not exceed thirty two (32) feet without a required flame break. (NFPA 1124 – 7.3.15.3.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
All shelving meets the requirements of NFPA 1124. (NFPA 1124 – 7.3.15.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Exits are marked by approved exit signs. (NFPA 1124 – 7.3.15.5.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Exit signs are self luminous or internally or externally illuminated. (NFPA 1124 – 7.3.14.5.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Emergency lighting is provided at each means of egress. (NFPA 1124 – 7.3.14.6.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Shelving, partitions, counters, cases and similar dividers do not exceed six (6) feet in height in the CFRS retail area. (NFPA 1124 – 7.3.15.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Merchandise on display or located on shelves or counters does not exceed six (6) feet in height in the CFRS retail area as measured from the floor. (NFPA 1124 – 7.3.15.2.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Merchandise located along the perimeter of the CFRS retail area does not exceed a height of twelve (12) feet. (NFPA 1124 – 7.3.15.2.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The maximum distance between flame breaks for continuous displays does not exceed sixteen (16) feet. (NFPA 1124 – 7.3.15.3.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
All electrical wiring is installed in accordance with the National Electric Code. (NFPA 1124 – 7.3.16)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Any heating units within the CFRS facility are listed and are used in accordance with the listing. (NFPA 1124 – 7.3.17.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Any temporary heating sources within the CFRS facility has tip over and temperature overheat protection. (NFPA 1124 – 7.3.17.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Portable generators that use Class II or Class III combustible liquids are limited to not more than five (5) gallons. If more, apply section 7.4.9.2.4. (NFPA 1124 – 7.3.18.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
No consumer fireworks are displayed within five (5) feet of any public entrance in an enclosed building or structure. (NFPA 1124 – 7.3.19.2.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFRS facility and stores is secured when unoccupied and not open for business unless fireworks are removed and not kept in the facility during such times. (NFPA 1124 – 7.3.19.3.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS facility is free from an accumulation of debris and rubbish. (NFPA 1124 – 7.3.21.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Damaged consumer fireworks have been removed and are not for sale. (NFPA 1124 – 7.3.21.5)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Records of available inventory are maintained on site. (NFPA 1124 – 7.3.24.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The maximum travel distance to a portable fire extinguisher is thirty five (35) feet of travel for temporary CFRS locations. (NFPA 1124 – 7.4.5.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
A sign which reads “NO FIREWORKS DISCHARGE WITHIN 300 FEET” shall be placed on each exterior side of the CFRS facility. The letters shall be at least four (4) inches high and on a contrasting background. (NFPA 1124 – 7.4.6.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS tent/canopy/membrane structure/stand is at least twenty (20) feet from any building (NFPA 1124 – 7.4.7.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS tent/canopy/membrane structure/stand is at least thirty (30) feet from combustible materials, including dry grass and dry brush. (NFPA 1124 – 7.4.7.2 and 7.4.6.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS tent/canopy/membrane structure is at least twenty (20) feet from any other tent/canopy/membrane structure. (NFPA 1124 – 7.4.7.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS tent/canopy/membrane structure is at least twenty (20) feet from any other CFRS stand. (NFPA 1124 – 7.4.7.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS stand is at least five (5) feet from any other CFRS stand. (NFPA 1124 – 7.4.7.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

	Pass/Yes	Fail/No	N/A
The CFRS tent/canopy/membrane structure/stand is at least twenty (20) feet from any CFRS storage. (NFPA 1124 – 7.4.7.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS tent/canopy/membrane structure/stand is at least twenty (20) feet from any vehicle parking. (IFC 2006 – 2403.8.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The CFRS facility has an evacuation plan posted in a conspicuous location(s) that is accessible to the public and persons working in the CFRS facility. (NFPA 1124 – 7.4.8.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Exit openings from tents shall be a minimum width of at least forty four (44) inches. (NFPA 1124 – 7.4.8.5)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Portable generators shall be located at least twenty (20) feet from the CFRS facility when tanks are five (5) gallons or less in capacity. (NFPA 1124 – 7.4.9.2.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Portable generators shall be located at least fifty (50) feet from the CFRS facility when tanks are greater than five (5) gallons in capacity. (NFPA 1124 – 7.4.9.2.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fuel for portable generators is stored at least twenty (20) feet from the CFRS facility. (NFPA 1124 – 7.4.9.2.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cooking equipment of any type is located at least twenty (20) feet from the CFRS facility. (NFPA 1124 – 7.4.9.3.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Open flame cooking equipment of any type is located at least fifty (50) feet from the CFRS facility. (NFPA 1124 – 7.4.9.3.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
A sign stating “NOTICE: Use of fireworks, including permissible consumer fireworks in not allowed in the City of Peoria” at each point of sale location. (City of Peoria Code 9-49(a) (1)).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
A sign stating “Consumer fireworks authorized for sale under state law may not be sold to persons under the age of 16” at each point of sale location. (City of Peoria Code 9-49(a) (1)).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

- Storage of consumer fireworks related to retail sales at CFRS facilities must comply with Chapter 7. (NFPA 1124 – 1.3.2.3.2)
- Trailers, semitrailers and metal shipping containers that are not normally occupied are not required to comply with the Life Safety Code (NFPA 1124 – 6.8.2)
- Requirements in Chapter 7 shall not apply to CFRS facilities that are under the exempted amount. Five hundred (500) pounds for non sprinklered facilities and one thousand (1,000) pounds for sprinklered facilities. (NFPA 1124 – 7.3.1.1)
- Heaters with open flame or exposed elements are prohibited. (NFPA 1124 – 7.3.17.3)
- A building permit from Building Safety is not required for any structure that is two hundred (200) square feet or less. This structure cannot have any electrical inside or attached to the structure.

**Table 7.4.7.2 Temporary CFRS Facilities – Minimum Separation Distances**

	Buildings	Combustibles	Tents	Vehicle Parking	Stands	Storage of Consumer Fireworks
Tents	20 feet	20 feet	20 feet	20 feet (*)	20 feet	20 feet
Stands	20 feet	10 feet	20 feet	10 feet	5 feet	20 feet

(\*) Modified under the requirements of the IFC section 2403.8.2.

For items that are marked as N/A explain the reason why.

---



---



---

Notes or comments.

---



---



---