



# Peoria Fire Department



## Plan Review Guide for Site Plans

Site plans submitted for review and approval shall contain the following information.

1. \_\_\_\_\_ Scaled drawings provided.
2. \_\_\_\_\_ Required fire lanes, emergency access roadways and emergency vehicle turnarounds are outlined and dimension are marked and identified on the drawing.
3. \_\_\_\_\_ Type of material used for the fire access roads
4. \_\_\_\_\_ Type of construction of the building and location to the property line.
5. \_\_\_\_\_ Fire lane sign locations and the sign detail are shown on the drawing.
6. \_\_\_\_\_ Any gates or other barriers limiting 24-hour access to the site are shown on the plans. Key Switch & Pre-emption locations are shown on the plans.
7. \_\_\_\_\_ The locations and minimum number of fire hydrants, fire department connections are identified on the drawing.
8. \_\_\_\_\_ A symbol list showing symbols used on drawings and its description.
9. \_\_\_\_\_ Fire line into the building.